

Certificate No. **354-3-7135**
Date: **4 November 2008**

1 Certificate Holder

Name: Jackpad Limited
Address: 1 Moathouse Road, Kirton in Lindsey, Gainsborough North Lincolnshire DN21 4DD
Email: enquiries@jackpad.co.uk
Tel: 01652 640753

2 System Title

Description: The Jackpad System-comprising Jackpad 400 Support Block, 2 section Steel Adjuster & 50mm incremental packer

3 The system has been assessed on the following drawings and documents:

Jackpad product information pack issue 1. Letters from John Strange Chartered Structural Engineers dated 23/9/05, 24/10/05 & 19/11/05. Test sheets from Humberside Materials Laboratory M/03799/1,3,4 M/08149/1-5 M/08313/1-3 M/12233/1-2.

The imposed load per Jackpad is no greater than 48kn and the ground bearing pressure is no less than 130kn/m², otherwise additional dispersion measures must be undertaken on a project specific basis.

Extent of Recommended Regulatory Approval: Part A

4 Assessment

The design and method of construction of the system designed in (2) above has been examined and as far as it has been shown has been found to be capable of complying with current Building Regulations.


5 Conditions of Certification

1. The design shown and the materials specified shall not be changed without reference to the local authority responsible for certifying the system.
2. The certificate shall be valid for three years or until invalidated by formal notice.
3. Where reference is made on a plan to any Code of Practice, British Standard or manufacturer's instruction it shall be construed as a reference to such publication in the form in which it is in force at the date of this certificate.
4. This certificate should not be regarded as a formal approval under the Building Regulations.

6 Authority

This system approval certificate is authorised by:

Name: Martin Salmon

Signature: 

On behalf of: North Lincolnshire Council